

21/1



CITY OF VANCOUVER

License OFFICE

CITY HALL

Jan. 30th, 1941.

Alderman H. D. Wilson,
CITY HALL.

Dear Alderman:-

As requested by you I am enclosing herewith
list of Ladies Dress Manufacturers in the City of Vancouver.

I trust this is the information you are want-
ing.

Yours very truly,

H. A. Hinguhart

LICENSE INSPECTOR.

EML.

*Geo. Easton
480 Rupert St.*

LIST OF MANUFACTURERS
OF
LADIES DRESSES

Sweet Sixteen Limited	-	137 West Hastings St.
Reliable Garment Co. Ltd.	-	339 Water Street
Madame Runge Ltd.	-	2566 Granville St.
E. Kamitakahara	-	2525 Oak Street
Fitwell Garments Ltd.	-	215-25/119 West Pender St.
S. J. North (United Garment Co)	-	316-18/119 West Pender St.
D. Shaffer (B.C. Garment Co.)	-	211/119 West Pender St.
R. Blumberg (Original Dress Co.)	-	2-3/445 Richards St.
M. Shinkoda	-	226 Powell St.
Vancouver Dry Goods Ltd.	-	136 Water Street
K. Iwata	-	368 East Cordova St.
Y. Suzuki	-	504 East Cordova St.
M. Sumiuya	-	640 East Cordova St.

21/2



CITY OF VANCOUVER

HEALTH OFFICE

CITY HALL

Copy for Alderman Wilson

August 18th, 1941.

H. Urquhart, Esq.,
City License Inspector,
City Hall, City.

Dear Sir:-

Re: " " "
Lux Cleaning, Dyeing & Repairing
Shop, 3185 Oak Street.

I have been requested to report on conditions existing at the above premises.

The office and repair room in the front of the building consists of one room 14' x 18' with a partition 8' in height between this and the remainder of the building.

The center portion of the building consists of a room, 280 sq. feet, in which are three double beds providing sleeping accommodation, according to the information available, for one man, wife and four children. According to the accepted standards, the floor area which would be necessary to accommodate these would be a minimum of 216 square feet, so that there is ample room for their requirements. We are advised that two other children of this family are living elsewhere with a relative.

There is a 4' passageway leading down the building to the kitchen, which is separated from the sleeping apartment by a 6' partition. The kitchen, which is at the rear and amply lighted with large windows, is 18' x 14' and contains a toilet room 5' x 6' and is provided with a sink. The ceiling is 12' 8" throughout, affording ample light and ventilation above the partitions.

This building was first seen by our District Inspector on July 29th, when it was found that a mezzanine floor had been built for sleeping accommodation and partitions raised beyond the legal limit. The owner and tenants were notified that this was not satisfactory and the attention of the Building Department drawn to the same. On August 5th, further inspection revealed that the orders issued by the Building Department had been complied with.

Yours truly,

Stewart Murray
MEDICAL HEALTH OFFICER.

CEB:EM
Copy to Alderman Wilson.